

The Louisiana School for Math, Science and the Arts is soliciting bids for the removal and disposal of an old chiller and the replacement and installation of a new chiller system.

- The chiller to be removed is a Carrier 19D water cool chiller from 1983:
 - Model #19DK5052CC
 - Serial #84-11-35280
 - 460 volts
 - 3/60 PH/HZ
 - 210 Ton Capacity
- The replacement chiller will be a new AquaForce/Carrier water-cooled screw chiller system, or equivalent.
 - Tag name 30HXC CH-1
 - Model #30HXC206
 - 460 volts
 - 3/60 PH/HZ
 - 209 Ton Capacity

Vendor will furnish all parts, labor and equipment necessary for the completion of the water cool chiller removal/replacement project as specified:

- Report to Plant Supervisor, Henry Llorence, on arrival.
- Remove piping and electrical.
- Remove Carrier 19D water cool chiller with a crane.
- Install new AquaForce/carrier water-cooled screw chiller system with a crane.
- Re-pipe as needed.
- Install electrical as needed.
- Insulate piping as needed.
- Start unit and check for proper rotation and operation.
- Work to be performed between 8:00 AM and 4:00 PM.
- Clean work area and remove all trash.