



“RE-BUILDING THE CITY’S WATER SYSTEMS FOR THE 21ST CENTURY”

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 504-529-2837 OR 52-WATER
www.swbno.org

Addendum No. 1

Date: 10/6/2023

Your reference is directed to **Contract Number: ME23-0031** for DPS 10 Pump Assembly and Commissioning at DPS 10 (9600 Haynes Blvd), which is scheduled to be received at **11:00 a.m. CST on October 26, 2023**.

This addendum provides for the following:

Question:

1. How the pump is going to be returned to the station. Will it be delivered there by SWBNO? Will it be placed inside as it was left, or will the contractor have to move it inside?

Answer:

2. The pump will be delivered by truck to DPS10 by the OEM. The contractor will be responsible for unloading the pump from the truck and staging it inside the station for installation.
3. The inquiry period for questions have been extended to November 9, 2023, at 5p.m. The quote due date has been extended to November 30, 2023, at 11:00 a.m.
4. The pump should arrive at the station with an assembled lower bowl assembly (lower shaft, impeller, diffuser, impeller cone, upper diffuser bearing housing, etc.). The pump column will arrive as a separate item, the discharge elbow/head will arrive as a separate item, the upper shaft will be a separate item, the upper shaft tube and stuffing box will be one assembly, and there will be a pallet of the smaller parts, hardware, and intermediate coupling. This is the repair vendor’s current estimated shipment breakdown to be used for information only.

The above revisions shall be incorporated in and take precedence over any conflicting part of the original proposal documents. This addendum is hereby officially made a part of the referenced proposal.

Receipt of this addendum shall be acknowledged by inserting its number and date in the space provided in the Form of Proposal.

This addendum consists of one (1) page.

*** END OF ADDENDUM ***