



“RE-BUILDING THE CITY’S WATER SYSTEMS FOR THE 21ST CENTURY”

Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

November 13, 2023

Addendum No. 3

Your reference is directed to the Request for Quotation for **2023-SWB-20 – CONTRACT 5251 - NDR GRANT ADDITIONAL INSTRUMENTATION PROJECT (Rebid)** for the Sewerage and Water Board of New Orleans proposals that are due on **November 14, 2023, at 11:00 a.m. (CST)**.

This addendum provides for the following:

1. Bid Timetable Revision
2. Questions and Responses

Correction in Instruction to Bidders

- 1) Response to inquiries will be posted on November 13, 2023.**
- 2) Bid Due Date: November 29, 2023, at 11:00 a.m.**
- 3) Bid Opening: November 29, 2023, at 11:30 a.m.**

Microsoft Teams Meeting (Bid Opening)

Join on your computer, mobile app, or room device

[Click here to join the meeting](#)

Meeting ID: 218 698 042 154

Passcode: fH8sFy

[Download Teams](#) | [Join on the web](#)

Or call in (audio only)

[+1 504-224-8698,709780236#](#) United States, New Orleans

Phone Conference ID: 709 780 236#

Questions and Responses

- 1) The contract amount of \$1.19 million is too low to complete this scope of work. Is more funding available?

The Board expects that cost proposals will exceed the \$1.19 million currently allocated to this project. Proposals do not need to be under \$1.19 million to be considered.

- 2) The response to question #2 in addendum 2 appears to direct the contractor to include new 120V panels for the entire project and to also include this cost in bid item 14. If so, then please provide the desired number of panels to include, since the drawings and specs do not provide this.

Please assume that contractor will install cabling and rigid conduit to existing panels and that no new panels will be installed.

***PLEASE NOTE: FOR CLARIFICATION, THE FOLLOWING QUESTION AND RESPONSE REPLACES QUESTION/RESPONSE #2 FROM ADDENDUM 2).**

- 3) We assume all new 120V power circuits required for anything will come from existing 120V panels and breakers already inside each station. Is that correct?

Yes.

The changes, additions, and/or deletions included herein are hereby made part of the Contract Documents for CP-5251 NDR Grant-Additional Instrumentation Project, as fully and completely as if the same were set forth therein. The bidder shall acknowledge receipt thereof on the form of proposal. This addendum consists of (2) pages.

***** END OF ADDENDUM ****