

**Addendum #6**

**March 22, 2024**

**Solicitation # 2024-Northtransitcenter-001**

**ITB Due Date**

**10:00am (CDT) – April 8, 2024**

The Capital Area Transit System (CATS), Baton Rouge, Louisiana hereby amends the above referenced Invitation to Bid (ITB) as follows:

- 1. Addendum to provide a copy of the sign-in sheets from the Non-Mandatory Pre-Bid Conference.**
- 2. CATS Official Responses to ITB Questions and Approved equal requests.**

The following questions were submitted in writing by prospective bidders and/or suppliers.  
This document represents CATS official responses /clarifications to written questions.

<b>WRITTEN QUESTIONS RECEIVED</b>		<b>CATS OFFICIAL RESPONSES TO WRITTEN QUESTIONS</b>
1.	What is the estimated construction budget?	RS 38:2212 H. The estimate of probable construction costs for the project shall be made available at the time of bid opening, either by posting such estimate electronically or announcing aloud such estimate at the bid opening.
2.	Request for approved Equal We are requesting designation as an approved manufacturer for the Tensile Structure scope for this project as outlined in Specification Section 133100 Fabric Structures and associated drawings.	Span Systems, Inc. can be considered as a substitute, based on the company information provided, to the basis of design manufacturer. Due to the system being a delegated design submittal, final approval would be considered following receipt of the 13 31 00 Fabric Structures submittal. Acceptance of Span Systems, Inc. as a manufacturer requires the design to meet all architectural and structural requirements without the necessity for redesign.
3.	Request for approved Equal Spec Section 133100 - 2, Page 302. Requesting to see if USA Shade can be approved as an approved manufacturer for the complete fabric shade structure system	Span Systems, Inc. can be considered as a substitute, based on the company information provided, to the basis of design manufacturer. Due to the system being a delegated design submittal, final approval would be considered following receipt of the 13 31 00 Fabric Structures submittal. Acceptance of Span Systems, Inc. as a manufacturer requires the design to meet all architectural and structural requirements without the necessity for redesign.
4.	Is there a project timeline?	Estimated 12 months construction.
5.	Light fixture Type E, NLS Lira Light Column NLS Lighting Catalog Number: LIR-6-SYM-88-40K8-UNV-8-ABFINISH-MGF-BAA	Approved



Print Please

**Non-Mandatory Pre Bid Conference Attendee List**  
**Solicitation #2023-Northtransfencer-008**

List of Attendees			
Attendee List Names	Company	Phone	Email
1. PATRICK DAUGHERTY	SIENNA CONSTRUCTION LLC	225-456-5466	bids@siennaconstruction.n
2. Brandon Chalkin	Guy Hopkins Construction	225 751 2158	estimating@gyuhopkins.com
3. GREG FLITTER	J.W. GRAND	225 767 3724	BIDS@JWGRAND.COM
4. Eric Turner	UPG Construction	205-936-9431	ETurner@VERJUSPROPERTY Con
5. Karl Landry	Spartan Building Corporation	985-845-2835	brice@spartanbuilding.com
6. Cheri Souleau	CATS		
7. —			
8. Donorhea Young	CATS		
9. Phonda Kimbel	CATS		

**Sign in Sheet**  
**Non-Mandatory Pre-Bid Conference**