



“RE-BUILDING THE CITY’S WATER SYSTEMS FOR THE 21ST CENTURY”

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

May 7, 2024

Addendum No. 3

Your reference is directed to **Contract 1443 – WEST POWER COMPLEX @ CWTP - CLAIBORNE WATER SUPPLY TIE-IN** for the Sewerage and Water Board of New Orleans which is scheduled to open at **11:30 a.m. Local time on May 10, 2024.**

This Addendum consists of 1 Page(s) and 1 Attachment(s).

This addendum provides for the following:

1. Section 01 31 13 – Project Coordination, Paragraph 3.04.A, ADD Paragraph 3.04.A.10 as follows:
 - a. If contractor intends to place equipment or materials on the concrete roof of the C-Basin passage that a portion of the pipe is mounted along, matting must be utilized. Matting should span entire C-Basin passage roof (minimum 10'-9") and be designed to support full load of equipment or material. A detailed plan must be submitted for review and approval by the Owner and Engineer prior to placement of any equipment or materials on the concrete passage roof.

The changes, additions, and/or deletions included herein are hereby made part of the Contract Documents for the CP-1443 West Power Complex @ CWTP – Claiborne Water Supply Tie-In project, as fully and completely as if the same were set forth therein. The bidder shall acknowledge receipt thereof on the Form of Proposal.

***** END OF ADDENDUM *****